



IEC 896-2 Compliance

According to IEC 896-2 for float charging, the expected amount of gas generated during the charging phase should be no more than 30×10^{-6} m³/cell* in normal temperature and every 30 days.

All our sealed lead acid batteries generate quite low volumes of gas during the float charging stage and, as such, they are in compliance with IEC 896-2.

It is important that any battery should be charged in accordance with best safety practices. Please refer to the corresponding battery specification sheet, Safety Data Sheets and our Technical Manual as featured on the Power-Sonic website. These documents may be accessed at www.power-sonic.com under the Products & Literature sections.

Please contact our Technical Department with any queries.

July, 2015